



MADISON COUNTY DEPARTMENT of HEALTH

Eric Faisst, Director of Public Health

Dr. John B. Endres, President of Board of Health

September 1, 2016

Mr. Mark Kupris
Brookfield Central School
P.O. Box 60
Fairgrounds Road
Brookfield, New York 13314

**Re: 2016 Sample Lead and Copper Monitoring
Brookfield Central School, (T) Brookfield
PWS# NY2602981**

Dear Mr. Kupris:

The Madison County Department of Health (MCDOH) has received sampling results for the 2016 Brookfield Central School lead and copper monitoring. After reviewing your sample results, the following observations about lead and lead result reporting were made:

Lead and Copper results

Sample Date	Client Sample ID	Copper mg/L	Lead ug/L
7/6/2016	Kindergarten Fountain	0.21	<5.0
7/6/2016	Gym Hall fountain	0.30	<5.0
7/6/2016	Café Fountain	0.39	<5.0
7/6/2016	Upstairs Hall Fountain	0.42	<5.0
7/6/2016	Downstairs 1 st floor fountain	0.44	<5.0

Copper mg/L
0.21
0.30
0.39
0.42
0.44
0.43

90th Percentile, Copper

The limit is 1300 ug/L
or 1.3 mg/L

Lead ug/L
<5.0
<5.0
<5.0
<5.0
<5.0
<5.0
<5.0

90th Percentile, Lead

The limit is 15 ug/L
or 0.015 mg/L

All of your results were less than the lead action level of 15 ug/l and the 90th percentile value for lead was below the lead action level.

